

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1483:161 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Mirtone, 90 Fieldstone Ct., Cheshire, CT 06410
Contact: Brad Miller (888) 649-9827 FAX (203) 699-3108

DESIGN: Models MGC-VM and MGCF-VM, multiple candela synchronizable strobe lights. The lights are only considered synchronized when used in conjunction with listees listed Model G1M-RM sync module (CSFM Listing No. 7300-1483:149), which may employ Edwards listed Model SIGA-CC1S Auto Sync Output Module (CSFM Listing No. 7300-1591:121). Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 16-33 VDC/vFWR
Candela: 15cd, 30cd, 75cd, or 95cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only and wall or ceiling mount.

MARKING: Listee's name, model number, electrical/candela rating, and UL label.

APPROVAL: Listed as strobe lights for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLF: 7125-1591:219

03-16-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager